



Stantec

**NIAGARA REGION WIND FARM
WIND TURBINE SPECIFICATIONS
REPORT**

File No. 160950269
April 2013

Prepared for:

Niagara Region Wind Corporation
277 Lakeshore Road East, Suite 211
Oakville, ON L6J 6J3

Prepared by:

Stantec Consulting Ltd.
300 – 675 Cochrane Dr, West Tower
Markham, ON L3R 0B8

Table of Contents

1.0	INTRODUCTION	1.1
1.1	PROJECT OVERVIEW	1.1
1.2	REPORT REQUIREMENTS.....	1.2

2.0	WIND TURBINES	2.1
2.1	SPECIFICATIONS.....	2.1
2.2	WIND TURBINE COMPONENTS.....	2.2

3.0	CLOSURE	3.1
4.0	REFERENCES	4.1

List of Tables

Table 1.1: Wind Turbine Specifications Report Requirements: O. Reg. 359/09	1.2
Table 2.1: Enercon E101 & E82 – Wind Turbine Specifications.....	2.1

List of Appendices

Appendix A Turbine Specifications from Manufacturer

1.0 Introduction

The purpose of the Wind Turbine Specification Report is to describe the design components, make and model of the turbines proposed for this Project, including noise emission levels. This report should be read in conjunction with the issuance of several other Technical Reports which provide further detail of Project design and operation, construction and decommissioning.

1.1 PROJECT OVERVIEW

Niagara Region Wind Corporation (NRWC) is proposing to develop, construct, and operate the 230 Megawatt (MW) Niagara Region Wind Farm (the Project) within the Townships of West Lincoln and Wainfleet and the Town of Lincoln within the Niagara Region and within Haldimand County in Southern Ontario, in response to the Government of Ontario's initiative to promote the development of renewable electricity in the province. Project infrastructure such as collector lines and transmission lines will be sited along the boundaries of the Township of Pelham and Town of Grimsby, but will be sited outside of these municipalities on the opposite side of the road.

The basic components of the Project include 77 wind turbine generators (80 potential locations identified) each with a rated capacity ranging from approximately 2.3 MW to 3.0 MW for a maximum installed nameplate capacity of 230 MW. An overhead and/or underground collection system connects each turbine to one of two transformer substations along a series of 34.5 kilovolt (kV) lines. Turbines are grouped into nine collector circuits that bring power (and data via fibre optic lines) to one of the transformer substations. Voltage is stepped up from 34.5kV to 115kV at each transformer substation by means of a 100 MVA base rated transformer with two stages of cooling (via fans). A 115kV transmission line transports power from each of the two transformer substations north to the tap-in location where the Project is connected to the Hydro One Networks Inc. (HONI) owned transmission line, south of the Queen Elizabeth Way (QEW) in the Town of Lincoln. Power generated from this Project will be conveyed along the existing HONI transmission line to the Beach Transformer Station in Hamilton.

Alternate transmission and collector lines routes have been identified and assessed to provide options during detailed design, the final selection of which route to follow will be confirmed following the consultation process with local distribution companies, agency review and detailed design.

Other Project components include access roads, junction boxes (or pad-mounted disconnect switches) and associated culverts at swales and waterbody crossings. Temporary components during construction may include temporary laydown areas (for storage and staging areas at each turbine location), crane pads or mats, staging areas along access roads, delivery truck turnaround areas, central construction laydown areas and crane paths.

1.2 REPORT REQUIREMENTS

This Wind Turbine Specifications Report is one component of the REA Application for the Project, and has been prepared in accordance with Item 13, Table 1 of O. Reg. 359/09 which sets out specific content requirements as provided in **Table 1.1**.

Table 1.1: Wind Turbine Specifications Report Requirements: O. Reg. 359/09

Requirements	Completed	Section Reference
The make, model, name plate capacity, hub height above grade and rotational speeds.	✓	2.1
The acoustic emissions data, determined and reported in accordance with standard CAN/CSA-C61400-11-07, "Wind Turbine Generator Systems — Part 11: Acoustic Noise Measurement Techniques", dated October 2007(or equivalent (IEC) standard 61400-11 (edition 2)), including the overall sound power level, measurement uncertainty value, octave-band sound power levels (linear weighted) and tonality and tonal audibility.	✓	2.1

2.0 Wind Turbines

2.1 SPECIFICATIONS

The Project will include 77 ENERCON wind turbine generators (80 potential locations identified) each with a rated capacity ranging from approximately 2.3 MW to 3.0 MW with a maximum installed nameplate capacity of 230 MW.

The selected wind turbine models for the Project are the ENERCON E101 and either the ENERCON E82 or a de-rated ENERCON E101 to achieve the contract capacity of 230 MW. Specifications of the E101 and E82 turbines are summarized below in **Table 2.1** and provided in **Appendix A**.

Both wind turbine models have been assessed with two hub height options (124m and 135m) in the REA application to provide operational flexibility. Final selection between the turbine models and hub heights will be determined during detailed design. The E101 turbine has higher sound emissions and a larger blade length than the E82. As a result, for the Technical Studies such as the Natural Heritage Assessment / Environmental Impact Study, Water Body and Water Body Assessment Report, Stage 1 and 2 Archaeological Assessments, Protected Properties Assessment and Heritage Impact Assessment, all turbines are assumed to be E101 turbines to account for the worst case scenario for feature setbacks and identification of potential negative impacts.

Some specific wind turbine model and hub height constraints have been identified through the Noise Assessment Report. Operational flexibility will not be provided for nine turbines which will have a hub height of 135m (T18, T36, T45, T46, T47, T53, T55, T60 and T74). Three of these nine turbines (T36, T46 and T53) will also be either E82 turbines or de-rated E101 turbines, the selection of which will be determined during detailed design on condition that the final selection meets the noise emission limits highlighted in the Noise Assessment Report. Additional information with respect to the sound power level for the ENERCON E101 and E82 turbines are provided in the **Noise Assessment Report (Appendix C of the Design and Operations Report)** provided under separate cover).

	ENERCON	ENERCON
Manufacturer	ENERCON	ENERCON
Model	E101	E82
Name plate capacity (MW)	3 MW	2.3 MW
Hub height above grade	124 m or 135 m *	135 m
Blade length	48.6 m	38.8 m
Rotor diameter	101 m	82 m
Rotor sweep area	8,012 m ²	5,281 m ²
Nominal revolutions (rotational speed)	4 – 14.5 rpm	6 – 18 rpm

Table 2.1: Enercon E101 & E82 – Wind Turbine Specifications		
Cut-in and cut-off wind speeds	2.5 m/s (cut-in) 28 – 34 m/s (cut-out)	2.5 m/s (cut-in) 28 – 34 m/s (cut-out)
Frequency	50 Hz or 60 Hz	50 Hz or 60 Hz
Sound Power Levels (Maximum Power for entire operation wind speed from cut in to cut off)	104.8 dBA	103.3 dBA
Tonal Audibility	$\Delta L_{a,k} \leq 2$ dB	$\Delta L_{a,k} < 2$ dB

* The hub height will be confirmed during detailed design and therefore both options have been carried through the REA assessment.

Operation of wind turbines between cut-in and cut-off wind speeds will generate noise. Appendix C of the **Noise Assessment Report** includes a Summary of the Test Report from Kotter Consulting Engineers for the E-101 3.0 MW turbine and E-82 2.3 MW turbine (German) demonstrating that the sound power level at 95% of the rated power is 104.8 dBA and 103.3 dBA respectively. Noise emissions are assessed in the **Noise Assessment Report, Appendix C** in the **Design and Operation Report**.

2.2 WIND TURBINE COMPONENTS

Each wind turbine consists of the following key components, each of which are further described in the Design and Operations Report and Project Description Report. These components are similar for the E101 turbine, E82 turbine and de-rated E101 turbine.

- Reinforced concrete tower foundation;
- 21 concrete tower sections for the 124 m hub height tower (or 24 concrete tower sections for the 135 m hub height tower);
- 3 steel tower sections;
- Nacelle (comprised of electrical generator and housing);
- Three rotor blades;
- Hub (the structure to where the blades attach);
- Power converter;
- Step-up transformer; and
- Electrical wiring and grounding.

The tower is supported by a concrete foundation, approximately 5 m deep and 25 m wide with piles as required, depending upon subsurface conditions. The specific size and design of each foundation will be confirmed following geotechnical investigations to be completed at each turbine location.

The towers consist of separate, pre-fabricated concrete segments produced in two or three half shells to allow for transportation. After assembly, the segments are linked to each other as

inseparable units by means of pre-stressing tendons inside the tower that are connected to the foundation. Three tubular steel tower sections at the top of the turbine are erected and bolted together on top of the precast concrete tower sections.

The tower supports the nacelle, which houses the main components of the wind turbine (comprised of electrical generator and housing). The nacelle cover is made of aluminum and is accessible from the tower via a hatch in the base frame.

Inside the base of each tower a step-up transformer transforms the power to a standard operating power line voltage (i.e. 400 V to 34.5 kV). A converter converts the power from direct current to alternating current in the tower base.

The 101 m diameter rotor consists of three blades and a hub. The blade design requires a strong structure to face high wind loads but also lightweight construction to minimize the load transmission to the nacelle. The blades for the E101 and E82 turbines are 48.6 m and 38.8 m in length, respectively. The pitch of the blades is adjustable, allowing maximum energy input from the wind and also acting as a braking system.

Electrical wiring includes cabling, which runs down the turbine tower to the transformer, converter and switchgear located at the base of the tower. From the switchgear, the 34.5 kV collection system transmits power from the turbines to one of two transformer substations.

The blades will be equipped with a blade de-icing system that detects conditions for potential ice formation and heats the blades to prevent the buildup of ice during winter operation. In addition, the controls of the turbine will detect if ice has accumulated on the blades during extreme weather events and will shut down operation. Wind turbine operation would not resume until the ice has melted.


Turbines would be lit with navigation lights on the top of the nacelles in accordance with Transport Canada Regulations and Standards as described in the Design and Operations Report.

3.0 Closure

The Niagara Region Wind Farm Wind Turbines Specifications Report has been prepared by Stantec Consulting Ltd. for Niagara Region Wind Corporation in accordance with Item 13, Table 1 of O. Reg. 359/09. Information compiled in this report has been provided in association with ENERCON, with additional support from Hatch Ltd., PCL Construction Ltd., and the Niagara Region Wind Corporation.

This report has been prepared by Stantec for the sole benefit of Niagara Region Wind Corporation, and may not be used by any third party without the express written consent of Niagara Region Wind Corporation. The data presented in this report are in accordance with Stantec's understanding of the Project as it was presented at the time of reporting.

STANTEC CONSULTING LTD.



Julia Kossowski
Project Manager
Tel: 519-576-5036
Fax: 519-579-6733
Julia.Kossowski@stantec.com



Chris Powell, M.A.
Project Manager, Environmental Planner
Tel: 519-585-7416
Fax: 519-585-4239
Chris.Powell@stantec.com



J.A. (Al) Leggett, BA, MCIP, RPP
Principal, Environmental Management
Tel: 905-415-6384
Fax: 905-474-9889
Al.Leggett@stantec.com

4.0 References

Ontario Ministry of the Environment (MOE). 2012. Technical Guide to Renewable Energy Approvals, as amended.

O. Reg. 359/09. 2012. Ontario Regulation 359/09 made under the Environmental Protection Act, Renewable Energy Approvals Under Part V.0.1 of the Act, as amended by O. Reg. 333/12 on November 2, 2012.

Appendix A


Turbine Specifications from Manufacturer

E101

3,000 kW



Calculated power curve



Wind [m/s]	Power P [kW]	Power coefficient Cp [-]
1	0.0	0.000
2	3.0	0.076
3	37.0	0.279
4	118.0	0.376
5	258.0	0.421
6	479.0	0.452
7	790.0	0.469
8	1,200.0	0.478
9	1,710.0	0.478
10	2,340.0	0.477
11	2,867.0	0.439
12	3,034.0	0.358
13	3,050.0	0.283
14	3,050.0	0.227
15	3,050.0	0.184
16	3,050.0	0.152
17	3,050.0	0.127
18	3,050.0	0.107
19	3,050.0	0.091
20	3,050.0	0.078
21	3,050.0	0.067
22	3,050.0	0.058
23	3,050.0	0.051
24	3,050.0	0.045
25	3,050.0	0.040

$\rho = 1.225 \text{ kg/m}^3$

For more information on the ENERCON power curve, please see the last page.

Technical specifications E-101

Rated power: 3,000 kW
 Rotor diameter: 101 m
 Hub height: 99 m / 135 m
 Wind zone (DIBT): WZ III
 Wind class (IEC): IEC/NVN IIA

WEC concept: Gearless, variable speed
 Single blade adjustment

Rotor

Type: Upwind rotor with active pitch control
 Rotational direction: Clockwise
 No. of blades: 3
 Swept area: 8,012 m²
 Blade material: GRP (epoxy resin);
 Built-in lightning protection
 Rotational speed: Variable, 4–14.5 rpm
 Pitch control: ENERCON single blade pitch system;
 one independent pitch system per rotor blade with allocated emergency supply

Drive train with generator

Hub: Rigid
 Main bearing: Double-row tapered / cylindrical roller bearings
 Generator: ENERCON direct-drive annular generator

Grid feed: ENERCON inverter

Brake systems: – 3 independent pitch control systems with emergency power supply
 – Rotor brake
 – Rotor lock, latching (15°)

Yaw system: Active via yaw gear, load-dependent damping

Cut-out wind speed: 28–34 m/s (with ENERCON storm control*)

Remote monitoring: ENERCON SCADA

* For more information on the ENERCON storm control feature, please see the last page.



- 1 Main carrier
- 2 Yaw drive
- 3 Annular generator
- 4 Blade adapter
- 5 Rotor hub
- 6 Rotor blade

WIND ENERGY CONVERTER CHARACTERISTICS E-101

Rotor	
Type	E-101
Rotor diameter	101 m
Swept area	8012 m ²
Power regulation	Pitch
RPM	4 – 14,5 min ⁻¹
Cut in wind	2,5 m/s
Cut out wind	28 – 34 m/s
Survival wind speed	59,5 m/s

Gear Box	
Not applicable	No gearbox

Blades	
Manufacturer	ENERCON
Blade length	48,5 m
Material	GRP (Epoxy)
Lightning protection	included

Generator	
Manufacturer	ENERCON
Nominal Power	3000 kW
Type (model)	Synchronous, direct-drive ringgenerator
Protection classification	IP 23
Insulation class	F

Yaw System	
Type	electrical motors
Yaw control	Active (based on wind vane signal)
Yaw rate	0,5°/sec

Controller	
Manufacturer	ENERCON
Type	microprocessor
Grid connection	Via ENERCON inverter
Remote communication	ENERCON Remote Monitoring System
UPS	included

Braking System	
Aerodynamic brake	<ul style="list-style-type: none"> - three independent blade pitch systems with emergency supply - rotor brake - rotor lock, locking at 30°

Tower			
Hub heights	99 m	135 m	
Tower	Prefab concrete	Prefab concrete	
Design Wind Class	IIA	IIA	

Sources: Design Assessment

© by ENERCON GmbH. All rights reserved.			
Created/Date:	M. Lüninhöner	Checked:	AH/09/2009
Dpt.:	SL_HB	Approved:	SL_HB_WEC Characteristics_E-101_Rev001_eng-eng.doc
Revision:	001/31.03.2010	Reference :	

Vorläufiger Auszug aus dem Prüfbericht											
Stamtblatt "Geräusche", entsprechend den "Technischen Richtlinien für Windenergieanlagen, Teil 1: Bestimmung der Schallemissionswerte"											
Rev. 18 vom 01. Februar 2008 (Herausgeber: Fördergesellschaft Windenergie e.V. Stresemannplatz 4, D-24103 Kiel)											
Auszug aus dem Prüfbericht 213121-01.01											
zur Schallemission einer Windenergieanlage vom Typ E-101											
Allgemeine Angaben		Technische Daten (Herstellerangaben)									
Anlagenhersteller:	Enercon GmbH	Nennleistung (Generator):	3.0 (3.25) MW								
Seriennummer:	1010002	Rotordurchmesser:	101 m								
WEA-Standort (ca.):	49733 Haren	Nabenhöhe über Grund:	99 m								
Standortkoordinaten:	RW: 25.76.214	Turmbauart:	Beton								
	HW: 58.59.856	Leistungsregelung:	Pitch								
Ergänzende Daten zum Rotor (Herstellerangaben)		Ergänzende Daten zu Getriebe und Generator (Herstellerangaben)									
Rotorblatthersteller:	Enercon	Getriebehersteller:	entfällt								
Typenbezeichnung Blatt:	E-101-1	Typenbezeichnung Getriebe:	entfällt								
Blatteinstellwinkel:	variabel	Generatorhersteller:	Enercon								
Rotorblattanzahl:	3	Typenbezeichnung Generator:	G-101/30-G2								
Rotordrehzahlbereich:	5 - 14,7 U/min	Generatorumdrehzahl:	14,7 U/min								
Leistungskurve: Leistungskennlinie E101 3 MW OM I (berechnet) der Enercon GmbH zur E-101 vom 05.07.2012											
	Referenzpunkt		Schallemissions-Parameter	Bemerkungen							
	Normierte Windgeschwindigkeit in 10 m Höhe	Elektrische Wirkleistung									
Schalleistungs-Pegel $L_{WA,P}$	6 ms^{-1}	1.414 kW	103,6 dB(A)								
	7 ms^{-1}	2.077 kW	104,3 dB(A)								
	8 ms^{-1}	2.751 kW	104,7 dB(A)								
	9 ms^{-1}	2.987 kW	104,6 dB(A)	(2)							
	10 ms^{-1}	3.050 kW	-- dB(A)	(1)							
	8,3 ms^{-1}	2.850 kW	104,8 dB(A)								
Tonzuschlag für den Nahbereich K_{TN}	6 ms^{-1}	1.414 kW	0 dB bei 116 Hz								
	7 ms^{-1}	2.077 kW	0 dB								
	8 ms^{-1}	2.751 kW	0 dB								
	9 ms^{-1}	2.987 kW	0 dB	(2)							
	10 ms^{-1}	3.050 kW	-- dB	(1)							
	8,3 ms^{-1}	2.850 kW	0 dB								
Impulszuschlag für den Nahbereich K_{IN}	6 ms^{-1}	1.414 kW	0 dB								
	7 ms^{-1}	2.077 kW	0 dB								
	8 ms^{-1}	2.751 kW	0 dB								
	9 ms^{-1}	2.987 kW	0 dB	(2)							
	10 ms^{-1}	3.050 kW	-- dB	(1)							
	8,3 ms^{-1}	2.850 kW	0 dB								
Terz-Schalleistungspegel für $v_6 = 8,3 ms^{-1}$ in dB(A) entsprechend dem maximalen Schalleistungspegel											
Frequenz	50	63	80	125	160	200	250	315	400	500	630
$L_{WA,P,max}$	78,8	82,1	82,7	84,4	88,4	86,7	90,0	94,8	95,0	95,6	96,2
Frequenz	800	1.000	1.250	1.600	2.000	2.500	3.150	4.000	5.000	6.300	8.000
$L_{WA,P,max}$	95,0	93,3	91,5	90,4	86,6	85,4	83,7	80,8	75,8	69,7*	67,1**
Oktav-Schalleistungspegel für $v_6 = 8,3 ms^{-1}$ in dB(A) entsprechend dem maximalen Schalleistungspegel											
Frequenz	63	125	250	500	1.000	2.000	4.000	8.000			
$L_{WA,P,max}$	86,3	91,6	98,6	100,8	98,3	92,8	85,9	73,3**			

Dieser Auszug aus dem Prüfbericht gilt nur in Verbindung mit der Herstellerbescheinigung vom 13.03.2013.

Die Angaben ersetzen nicht den o. g. Prüfbericht (insbesondere bei Schallimmissionsprognosen).

- Bemerkungen:
- (1) Die normierte Windgeschwindigkeit von $v_6 = 8,3 ms^{-1}$ entspricht 95 % der Nennleistung.
 - (2) Witterungsbedingt keine Daten vorhanden
 - * Abstand zwischen Anlagengeräusch und Fremdgeräusch < 6 dB, Pegelkorrektur um 1,3 dB
 - ** Abstand zwischen Anlagengeräusch und Fremdgeräusch < 3 dB, keine Pegelkorrektur

Gemessen durch: KÖTTER Consulting Engineers GmbH & Co., KG

Datum: 13.01.2013

i. V. Dipl.-Ing. Oliver Bunk


i. A. Matthias Humpohl, B. Sc.

E82

2,300 kW



Calculated power curve



Wind [m/s]	Power P [kW]	Power coefficient Cp [-]
1	0.0	0.00
2	3.0	0.12
3	25.0	0.29
4	82.0	0.40
5	174.0	0.43
6	321.0	0.46
7	532.0	0.48
8	815.0	0.49
9	1,180.0	0.50
10	1,580.0	0.49
11	1,890.0	0.44
12	2,100.0	0.38
13	2,250.0	0.32
14	2,350.0	0.26
15	2,350.0	0.22
16	2,350.0	0.18
17	2,350.0	0.15
18	2,350.0	0.12
19	2,350.0	0.11
20	2,350.0	0.09
21	2,350.0	0.08
22	2,350.0	0.07
23	2,350.0	0.06
24	2,350.0	0.05
25	2,350.0	0.05

ρ = 1.225 kg/m³

For more information on the ENERCON power curve, please see the last page.

Technical specifications E-82 E2

Rated power: 2,300 kW
 Rotor diameter: 82 m
 Hub height: 78 m / 85 m / 98 m / 108 m / 138 m
 Wind zone (DIBT): WZ III
 Wind class (IEC): IEC/NVW IIA

WEC concept:
 Gearless, variable speed
 Single blade adjustment

Rotor
 Type: Upwind rotor with active pitch control
 Rotational direction: Clockwise
 No. of blades: 3
 Swept area: 5,281 m²
 Blade material: GRP (epoxy resin);
 Built-in lightning protection
 Rotational speed: Variable, 6–18 rpm
 Pitch control: ENERCON single blade pitch system;
 one independent pitch system per rotor blade with allocated emergency supply

Drive train with generator
 Hub: Rigid
 Main bearing: Double-row tapered / cylindrical roller bearings
 Generator: ENERCON direct-drive annular generator

Grid feed: ENERCON inverter
Brake systems: – 3 independent pitch control systems with emergency power supply
 – Rotor brake
 – Rotor lock

Yaw system: Active via yaw gear, load-dependent damping
Cut-out wind speed: 28–34 m/s (with ENERCON storm control*)

Remote monitoring: ENERCON SCADA

* For more information on the ENERCON storm control feature, please see the last page.



- 1 Main carrier
- 2 Yaw drive
- 3 Annular generator
- 4 Blade adapter
- 5 Rotor hub
- 6 Rotor blade

WIND ENERGY CONVERTER CHARACTERISTICS

E-82 E2 2.3MW

Rotor	
Type	E82 E2
Rotor diameter	82 m
Swept area	5281 m ²
Power regulation	Pitch
RPM	6 – 18 min ⁻¹
Cut in wind	2,5 m/s
Cut out wind	28 – 34 m/s
Survival wind speed	59,5 m/s

Gear Box	
Not applicable	No gearbox

Blades	
Manufacturer	ENERCON
Blade length	38,8 m
Material	GRP (Epoxy)
Lightning protection	included

Generator	
Manufacturer	ENERCON
Nominal Power	2300 kW
Type (model)	Synchronous, direct-drive ringgenerator
Protection classification	IP 23
Insulation class	F

Yaw System	
Type	6 electrical motors
Yaw control	Active (based on wind vane signal)
Yaw rate	0,5°/sec

Controller	
Manufacturer	ENERCON
Type	microprocessor
Grid connection	Via ENERCON inverter
Remote communication	ENERCON Remote Monitoring System
UPS	included

Braking System	
Aerodynamic brake	<ul style="list-style-type: none"> - three independent blade pitch systems with emergency supply - rotor brake - rotor lock, locking at 30°

Tower					
Hub heights	78 m	85 m	98 m	108 m	138 m
Tower	Steel (4 + FS)	Steel + Prefab concrete (2 + 15)	Steel + Prefab concrete (2 + 18)	Steel + Prefab concrete (2 + 21)	Steel + Prefab concrete (2 + 21)
Design Wind Class	II	II	II	II	II

Weights	
Nacelle, excl. Rotor and hub	Approx. 18 to
Rotor incl. Hub/Main pin	Approx. 55 to
Generator	Approx. 62 to
Total Weight	Approx. 135 to

Sources: Design Assessment, Manufacturers Certificate

Summary of Test Report (Measured hub height of 108 m) /1/												
Basic sheet "Geräusche" (Noise), according to the "Technische Richtlinien für Windenergieanlagen, Teil 1: Bestimmung der Schallemissionswerte" (Technical Guidelines for Wind Energy Converters, Part 1: Determination of sound emission values)												
Rev. 18 of February 1, 2008 (Editor: Fördergesellschaft Windenergie e.V. Stresemannplatz 4, D-24103 Kiel)												
Extract of Test Report 209244-04.01 IEC on noise emission of wind energy converter of type E-82 E2												
General Data				Technical Data (manufacturer's specifications)								
Manufacturer of WEC:	Enercon GmbH			Rated power (generator):	2,300 kW							
Serial number:	82679			Diameter of rotor:	82 m							
Location of WEC (ca.):	26629 Großefehn			Hub height above ground:	108 m							
Geographic co-ordinates:	GK longitude: 34.15.287			Type of tower:	conical tube tower							
	GK latitude: 59.14.701			Power control:	Pitch							
Complementary rotor data (manufacturer's specifications)				Complementary data of gear unit and generator (manufacturer's specifications)								
Manufacturer of rotor blade:	Enercon			Manufacturer of gear unit:	not applicable							
Type of rotor blade:	E-82 E2			Type of gear unit:	not applicable							
Blade setting angle:	variable			Manufacturer of generator:	Enercon							
Number of rotor blades:	3			Type of generator:	E-82 E2							
Rotor speed range:	6 to 18 r.p.m. (mode OM I)			Generator speed range:	6 to 18 r.p.m. (mode OM I)							
Calculated Performance Chart ENERCON E-82 E2; calculated by ENERCON (Rev. 3.0)												
	Reference Point		Noise emission parameters	Observations								
	standardized wind speed in 10 m height	true electrical power										
sound power level $L_{WA,P}$	5 ms^{-1}	579 kW	96.4 dB(A)									
	6 ms^{-1}	1,089 kW	100.6 dB(A)									
	7 ms^{-1}	1,612 kW	102.5 dB(A)									
	8 ms^{-1}	2,032 kW	103.2 dB(A)									
	9 ms^{-1}	2,255 kW	103.3 dB(A)									
tonal audibility $\Delta L_{a,k}$	10 ms^{-1}	2,300 kW	102.9 dB(A)									
	5 ms^{-1}	kW	- 2.7 dB									
	6 ms^{-1}	kW	<- 3.0 dB									
	7 ms^{-1}	kW	- 1.8 dB									
	8 ms^{-1}	kW	- 0.7 dB									
impulse adjustment for small distances K_{IN}	9 ms^{-1}	kW	0.2 dB									
	10 ms^{-1}	kW	- 0.4 dB									
	5 ms^{-1}	kW	0 dB									
	6 ms^{-1}	kW	0 dB									
	7 ms^{-1}	kW	0 dB									
	8 ms^{-1}	kW	0 dB									
	9 ms^{-1}	kW	0 dB									
	10 ms^{-1}	kW	0 dB									
Third-octave band sound power level for $v_s = 5 ms^{-1}$ in dB(A)												
Frequency	50	63	80	100	125	160	200	250	315	400	500	630
$L_{WA,P}$	74.1	76.5*	80.0	85.6	82.2	81.7	81.9	83.7	85.6	85.1	85.5	87.6
Frequency	800	1,000	1,250	1,600	2,000	2,500	3,150	4,000	5,000	6,300	8,000	10,000
$L_{WA,P}$	86.9	86.2	84.8	82.4	78.8	75.3	70.6	65.5	60.3*	60.3*	63.0	70.3
Octave band sound power level for $v_s = 5 ms^{-1}$ in dB(A)												
Frequency	63	125	250	500	1,000	2,000	4,000	8,000				
$L_{WA,P}$	82.3	88.3	88.8	91.0	90.8	84.5	72.1	71.4				
Third-octave band sound power level for $v_s = 6 ms^{-1}$ in dB(A)												
Frequency	50	63	80	100	125	160	200	250	315	400	500	630
$L_{WA,P}$	78.2**	79.1*	82.2	85.2	87.4	84.3	85.0	87.3	88.7	88.5*	89.5*	93.2
Frequency	800	1,000	1,250	1,600	2,000	2,500	3,150	4,000	5,000	6,300	8,000	10,000
$L_{WA,P}$	91.7	91.5	89.9	87.1	83.0	79.4	74.4	69.0	63.5	64.4	67.4	74.3

Octave band sound power level for $v_s = 6 \text{ ms}^{-1}$ in dB(A)												
Frequency	63	125	250	500	1,000	2,000	4,000	8,000				
$L_{WA,P}$	84.9*	90.6	92.0	95.7	95.9	89.0	75.8	75.4				
Third-octave band sound power level for $v_s = 7 \text{ ms}^{-1}$ in dB(A)												
Frequency	50	63	80	100	125	160	200	250	315	400	500	630
$L_{WA,P}$	78.6**	79.8	82.7	84.8	90.8	86.2	86.0	89.7	91.0	92.5	91.7	93.9
Frequency	800	1,000	1,250	1,600	2,000	2,500	3,150	4,000	5,000	6,300	8,000	10,000
$L_{WA,P}$	93.4	93.3	91.8	89.2	85.8	81.9	77.0	72.2	66.1	65.3	66.8	72.8
Octave band sound power level for $v_s = 7 \text{ ms}^{-1}$ in dB(A)												
Frequency	63	125	250	500	1,000	2,000	4,000	8,000				
$L_{WA,P}$	85.5*	92.8	94.2	97.6	97.7	91.4	78.5	74.4				
Third-octave band sound power level for $v_s = 8 \text{ ms}^{-1}$ in dB(A)												
Frequency	50	63	80	100	125	160	200	250	315	400	500	630
$L_{WA,P}$	77.4*	80.4	83.1	84.9	91.2	86.6	86.3	90.4	91.4	92.9	92.1*	94.8
Frequency	800	1,000	1,250	1,600	2,000	2,500	3,150	4,000	5,000	6,300	8,000	10,000
$L_{WA,P}$	94.2	94.1	92.6	90.1	86.7	82.7	77.8	73.3	67.7	65.8	66.6	71.4
Octave band sound power level for $v_s = 8 \text{ ms}^{-1}$ in dB(A)												
Frequency	63	125	250	500	1,000	2,000	4,000	8,000				
$L_{WA,P}$	85.6	93.2	94.6	98.2	98.5	92.2	79.4	73.4				
Third-octave band sound power level for $v_s = 9 \text{ ms}^{-1}$ in dB(A)												
Frequency	50	63	80	100	125	160	200	250	315	400	500	630
$L_{WA,P}$	78.5	81.4	83.9	85.7	92.6	88.2	86.4	90.2	90.7	91.8	91.5*	93.9
Frequency	800	1,000	1,250	1,600	2,000	2,500	3,150	4,000	5,000	6,300	8,000	10,000
$L_{WA,P}$	94.0	94.4	93.4	91.5	88.4	84.6	79.9	75.4	69.3	65.5*	66.4	71.5
Octave band sound power level for $v_s = 9 \text{ ms}^{-1}$ in dB(A)												
Frequency	63	125	250	500	1,000	2,000	4,000	8,000				
$L_{WA,P}$	86.6	94.6	94.3	97.3*	98.7	93.8	81.5	73.4				
Third-octave band sound power level for $v_s = 10 \text{ ms}^{-1}$ in dB(A)												
Frequency	50	63	80	100	125	160	200	250	315	400	500	630
$L_{WA,P}$	78.8	81.7	84.5	86.3	92.4	88.5	86.4	89.8	90.0*	91.2	90.9*	92.7*
Frequency	800	1,000	1,250	1,600	2,000	2,500	3,150	4,000	5,000	6,300	8,000	10,000
$L_{WA,P}$	93.3	93.9	93.3	91.5	88.8	85.2	80.7	76.5	71.9	70.4	68.5	71.8
Octave band sound power level for $v_s = 10 \text{ ms}^{-1}$ in dB(A)												
Frequency	63	125	250	500	1,000	2,000	4,000	8,000				
$L_{WA,P}$	87.0	94.6	93.7	96.5*	98.3	94.0	82.5	75.2				

This summary of the test report is valid only in combination with the certification of the manufacturer of 03/05/2010.

These specifications do not replace the test report mentioned above (particularly for noise immission predictions).

Observations: * Difference between working and background noise < 6 dB, correction by 1.3 dB
 ** Difference between working and background noise < 3 dB, values shall not be presented

/1/ Wind turbine generator systems – Part 11: Acoustic noise; measurement techniques (IEC 61400-11:2002 and A1:2006); German version DIN EN 61400-11:2007

Measured by: KÖTTER Consulting Engineers
 - Rheine -




Date: 08/02/2010

i. V. Dipl.-Ing. O. Bunk

i. A. Dipl.-Ing. J. Weinheimer